

MINISTRY OF DEFENCE OF THE CZECH REPUBLIC

Military establishment 8731 Prague

Testing laboratory of guard technical equipment

158 00 Praha 5, Pod Vodovodem 2

Tel.: 973 379 379 Fax: 973 379 351

Annex to No: 71-69/2011-8731



In Prague December 20, 2011

Copy No. 1

CONFORMITY ASSESSMENT

OF DEVICE OF INTRUSION AND HOLD-UP ALARM SYSTEMS

(Above the framework of testing Laboratory accreditation according to ČSN EN ISO/IEC 17025)

Order No: 171/21-69/2011	Registration No: 72-11/61/6
Type of device: Panic Button	Producer: Elmdene International Ltd.
Marking: ELM-PA-G3-W	Client: Elmdene International Ltd. 3 Keel Close, Interchnge Park Portsmouth Hampshire PO3 5QD UK
Assessment of device was performed on the basis of its properties test results in accordance with corresponding articles of ČSN EN 50131-1 standards (Test protocol No 164/11-301/2011 and No 164/11-305/2011).	
REALIZED LIMITING FACTS: Without limitations	
CONCLUSION OF THE ASSESMENT: Device: According to ČSN EN 50131-1 - fulfills requirements on security grade 4. high risk - fulfills requirements on environment class II – environment indoor general	
ISSUED: December 20, 2011	VALIDITY TILL: December 20, 2014
HEAD OF THE TESTING LABORATORY: Ing. Radek MOULIS  	HOLDER OF ASSESSMENT: stamp